



GENERATORS, ELECTRICAL AND TEMPORARY POWER

GENERAL:

Tents and membrane structures shall comply with all fire department regulations and all applicable adopted Town Codes.

Permits

- Generators and electrical systems do not require individual permits but are subject to inspection by the fire department and building department.

Generators

- Generators and other internal combustion power sources shall be separated from tents, canopies or membrane structures by a minimum of 20 feet
- Shall be isolated from contact with the public by fencing, enclosure, or other approved means.
- Shall be grounded in accordance with manufacturers specifications
- May not be refueled during times of public operation without prior

Fire Extinguishers

- A portable fire extinguisher with a minimum 2A10BC rating shall be provided for every generator
- Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use.

Power Cords and Adapters

- All extension cords shall be UL approved
- Extension cords shall be maintained in good condition without splices, deterioration or damage.
- Multi-plug adapters, such as cube adapters, un-fused plug strips or any other device shall be prohibited. Only surge protectors shall be used.
- All extension cords and power bars shall not be located in areas where water may accumulate.
- All power bars shall be plugged directly into single cords and may not be plugged into other multi-plug devices.
- All hanging lights or cords shall not cross egress paths less than 8 feet from the ground.
- Must be secured and or covered in areas of pedestrian travel
- Must have ramps over them in locations where a vehicle might cross

Lighting

- All lighting shall be specifically manufactured for the intended use. Open light bulbs strung from wire shall not be approved unless they have been designed for that purpose and all manufacturer hanging guidelines are met.
- Light fixtures shall only be used with lamps of the size intended by the manufacture.

Gilbert Fire Prevention Division
85 E Civic Center Drive, Gilbert, AZ 85296
Phone 480-503-6350 Fax: 480 503-6139
fireprevention@gilbertaz.gov